

ELEVATION (STREET SIDE)

SECTION B

WOOD PRIVACY FENCE

DATE: 18.03.19 SCALE: 1:25
PROJECT: 2198vention

DETAIL 2 - FOR GRADES EXCEEDING 4%

RESIDENTIAL SIDE (STANDARD PANEL)

DATE: 19.03.25 SCALE: 1:25
PROJECT: 2198vention

SECTION A (FENCE)

SECTION - WOOD PRIVACY FENCE

DATE: 19.03.25 SCALE: 1:10
PROJECT: 2198vention

BLACK VINYL - CHAIN LINK FENCE

DATE: 06.10.31 SCALE: 1:25
PROJECT: 2198vention

ELEVATION

SECTION A

DECORATIVE METAL FENCE

DATE: 20.08.06 SCALE: 1:25
PROJECT: 2198

ELEVATION

SIDE ELEVATION

SECTION A

SIGNAGE MASONRY WALL

DATE: 21.02.04 SCALE: 1:25
PROJECT: 2198

SECTION B

SECTION - SIGNAGE MASONRY WALL

DATE: 21.02.04 SCALE: 1:25
PROJECT: 2198

MASONRY NOTES

- CONCRETE FOUNDATIONS TO HAVE A MINIMUM COMPRESSIONAL STRENGTH OF 25 MPa @ 28 DAYS w/ 3-5% AIR ENTRAINMENT.
- CONCRETE TO BE READY-MIX MATERIAL SUPPLIED AND PLACED IN ACCORDANCE WITH CAN/CSA-A23, 1-04.
- CONCRETE BLOCK CORE TO BE UNIT MASONRY AS PER CAN S304.1-04.
- REINFORCING STEEL TO BE DEFORMED BARS WITH YIELD STRENGTH OF 400 MPa IN ACCORDANCE WITH CSA G30.18-18/19.
- SPICES IN REINFORCING TO HAVE MINIMUM OVERLAP OF 500 FOR 10M BARS, 750 FOR 15M BARS.
- ULTIMATE COMPRESSIVE STRENGTH OF MASONRY MATERIALS SHALL BE IN EXCESS OF: HOLLOW CONCRETE BLOCK - 15 MPa SOLID CONCRETE BLOCK - 12.4 MPa MORTAR - 12.4 MPa
- MORTAR TO BE AS SPECIFIED IN CAN/CSA-A173-04. ENSURE THAT WATER AND AGGREGATE USED IN MORTAR WILL NOT CAUSE EFFLORESCENCE.
- MORTAR COLOUR TO BE SELECTED BY LANDSCAPE ARCHITECT.
- CAVITY WALLS SHALL BE CONSTRUCTED SO THAT MORTAR DROPPINGS ARE PREVENTED FROM FORMING A BRIDGE TO ALLOW THE PASSAGE OF RAIN WATER ACROSS THE CAVITY.
- METAL BRICK TIES TO BE AS SPECIFIED IN CAN/CSA-S304.1-04.
- JOINTS BETWEEN PRECAST COPINGS AND SILLS REQUIRE THE APPLICATION OF HIGH QUALITY JOINT SEALER AND BACKER ROD.
- STONE SAMPLES TO BE SUPPLIED TO THE LANDSCAPE ARCHITECT FOR COLOUR SELECTION.
- FOR ALL PILLARS PROVIDE MIN. 25 AIR SPACE BETWEEN STONE FACE AND CONCRETE BLOCK. PROVIDE METAL TIES AT 400 O.C. HORIZONTAL. 400 O.C. VERTICAL. PROVIDE KEEP HOLES WITH PLASTIC COVERED SPACES AT 600 O.C. ALONG BOTTOM BOTTOM COURSE ONLY OR AT EACH JUNCTION OF BASE STONE PRECAST.
- MASON TO PROVIDE SAMPLE SECTION OF PILLAR FACING FOR APPROVAL OF LANDSCAPE ARCHITECT.
- STONE TYPE: TO BE COORDINATED WITH BUILDING STONE TO BE APPROVED BY LANDSCAPE ARCHITECT.
- SOIL PARAMETERS:
 - MIN. SOIL BEARING = 150kPa
 - MAX. K₀ = 0.4
 - MIN. K_φ = 2.5

cosburn nauboris LTD
landscape architects
DATE: 21.02.04 SCALE: 1:25
PROJECT: 2198

8	Issued for Submission	CMO	21 03 26
7	Issued for Submission	SW	21 03 17
6	Issued for Submission	CMO	21 02 25
5	For LSRCA Submission	CMO	21 02 17
4	For Submission to LSRCA	SW	20 08 20

No Revision By Yr Mo Da

All drawings and designs are the property of Cosburn Nauboris Limited and may not be used or reproduced without permission. This drawing must not be scaled.

Invalid Unless Signed Original

cosburn nauboris LTD
landscape architects
20 crown street dr suite 2 markham, on l3r 9v9
1 905 940 4443
cosburnnauboris.ca

24 REACH STREET
VENETIAN GROUP
TOWNSHIP OF UXBRIDGE

DETAILS

Drawn by: CMO Scale: AS SHOWN
Checked by: PHC Plot Date: 2021-03-26
Approved by: PHC Project: 2198

LD2
Drawing No.